



**CITY OF ATLANTIC CITY**

---

**CITY SOLICITOR'S OFFICE**

**G. BRUCE WARD  
CITY SOLICITOR**

CITY HALL - ROOM 406  
1301 BACHARACH BOULEVARD  
ATLANTIC CITY, N.J. 08401  
TELEPHONE (609) 347-5540  
TELECOPIER (609) 347-5210

IRVING B. JACOBY, DEPUTY CITY SOLICITOR  
ANTHONY A. SWAN, ESQ.  
MICHAEL J. PERUGINI, ESQ.  
BENJAMIN J. KAUFMAN, ESQ.

July 9, 2010

**Re: Solar Photovoltaic Power RFP- Second Addendum including extension of certain critical dates.**

To All Proposers:

Please find attached to this notice the City of Atlantic City's response to the Questions that were submitted by Barrier Electric on June 30, 2010. The City's response and attached documentation are to be considered addendum number two (2) to the original Request for Proposal (RFP).

Pursuant to N.J. S. A 40A:11-4.4 all potential vendors are being notified of this change to the RFP documentation.

Should you have any questions, or comments please contact me directly. Thank you.

Michael Perugini, Esq.  
Assistant City Solicitor

## **Solar Photovoltaic Power RFP**

### **Responses to Questions Submitted By Barrier Electric**

1. On page 51 in the RFP, confirm that we only need to supply spare fuses for the inverters and that we do not need to supply two (2) extra inverters.

**Inverters which are 10 kW or less in size, bidders should provide for two (2) extra inverters to remain on site all times. For inverters which are greater than 10kW in size, bidders should provide for two (2) replacement control power supplies and two (2) replacement control boards to remain on site at all times.**

- 2 PPA term in attachment A (page 19) is stated to be twenty (20) years, please clarify this is allowed by law or is it fifteen (15) years.

**No clarification or modification of the referenced specification is necessary. Bidder should bid pursuant to the procurement law and any alternative bidding process which may be appropriate.**

- 3 Please confirm who is the off taker of the electricity, electric bill payer, and owner of the building.

**Electricity generated by the project will be used to offset the amount of electricity purchased in connection with the Public Works building, with any excess electricity going through the City's meter and the City remaining responsible for the net bill, but the City is open to other arrangements which are consistent with the JPP. Such alternative arrangements would require bidder to obtain all necessary approvals.**

## **Second Addendum to RFP**

**The City draws the attention of all bidders to the following clarifications:**

1. Warranties provided for the inverters should include the inverters themselves and their operation, not just the mounting hardware.
2. A ballasted system supporting the panels may be incompatible with the requirement concerning wind uplift. The roof mounting proposed by bidder should be consistent with the mounting specifications provided in Addendum No. 1 to the RFP.
3. Notwithstanding the specifications on p.41 of the RFP, bidders should take the marine environment into account when proposing materials to be used in constructing and mounting the panels.